

# CERTIFICATE

## 0960-CPR-SKGIKOB.012057.05.ENG

Issued: 23-10-2023  
Valid until: 06-11-2025

Replaces: 0960-CPR-SKGIKOB.012057.04.ENG  
Issued: 17-06-2021



### Certificate holder

Byldis Facades BV  
De Run 4225  
5503 LM Veldhoven  
T: +31 (0)402 307 474  
E: facades@byldis.com  
I: www.byldis.com

## Certificate of constancy of performance

### Declaration of SKG-IKOB (Notified Body 0960)

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### FIRE RESISTING AND/OR SMOKE CONTROL DOORSETS AND/OR OPENABLE WINDOWS COVERED BY EN 14351-1

as specified in the attached appendix placed on the market under the name or trade mark of the holder of this certificate and produced by the holder of this certificate or for the holder of this certificate in the manufacturing plant(s) if mentioned above.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

### EN 16034:2014

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 06-11-2020 and will remain valid until the date as mentioned at this certificate as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

For SKG-IKOB

A handwritten signature in blue ink, appearing to be 'H.A.J. van Dartel', written over a horizontal line.

ir. H.A.J. van Dartel  
Certification manager

The users of this certificate are advised to verify at [www.skgikob.nl](http://www.skgikob.nl) if this certificate is still valid and actual.  
This certificate consists of 2 pages.



SKG-IKOB Certificatie  
Poppenbouwing 56  
4191 NZ Geldermalsen

Postbus 202  
4190 CE Geldermalsen

T 088-2440100  
info@skgikob.nl  
www.skgikob.nl

CERTIFICATE

# CERTIFICATE

Byldis Facades BV  
Number: 0960-CPR-SKGIKOB.012057.05.ENG

Page 2 of 2

## Appendix 1 CERTIFICATE OF CONSTANCY OF PERFORMANCE

	<b>Intended use:</b> Intended to be used in fire and/or smoke compartmentation and/or escape routes	
	<b>Specification</b>	<b>Levels and classes of performance</b>
1	<b>System:</b> WICONA WICSTYLE 77FP <b>Material:</b> aluminium	EW 30, EI2 30, EI2 60
2	<b>System:</b> WICONA WICLINE 75FP <b>Material:</b> aluminium	EW 20, EW 30, EI1 20, EI1 30, EI2 20, EI2 30
3	<b>System:</b> SAPA AVANTIS SMARTLINE 70 LIGNA FR <b>Material:</b> aluminium	EW 30, EI1 30, EI2 30
4	<b>System:</b> ALUPROF MB-86EI <b>Material:</b> aluminium	EW 20, EI1 20, EI2 20, EW 30, EI1 30, EI2 30
5	<b>System:</b> ALUPROF MB-78EI <b>Material:</b> aluminium	EW 30, EI2 30, EW 60, EI2 60, EW 90, EI2 90